



CERTIFICATE OF INSPECTION

Inspection Dated: 14/01/20

SMITHS FIRE LLP have serviced the **Portable Fire Appliances** in accordance with BS 5306:3 as detailed in Inspection Report 183415

Hunts Kart Racing Club Ltd
The Old Airfield
Stow Longa
Kimbolton
Cambridgeshire
PE28 0EY

8	6 Litre AFFF Extinguisher	1	6 Litre Wet Chem
21	6 Kg Dry Powder	12	9 Kg Dry Powder
1	1m x 1m Fire Blanket		

RETAIN THIS CERTIFICATE

your Fire Officer or Insurance Company may wish to see it

Service Technician: Kevin Holmes

As per British Standard requirements you should inspect your Portable Fire Appliances once per month for signs of discharge/lost pressure (where gauge is fitted)/ damage and that it is correctly located.

NB: service due date is month specific, not day specific

Smiths Fire LLP, Northfield Point, Cunliffe Drive, Kettering, Northants NN16 9QJ
01536 484846 sales@smithsfire.com

Registered in England No. OC339948