

FIRE SAFETY & SECURITY LTD

Mr G W Wood
1 Raps Green
TAUNTON
Somerset
TA1 2UT

Telephone: 01823 271182

Mobile: 0784 365 2121

Email: gordonwood27@msn.com

CERTIFICATE OF INSPECTION

Customer Name: MANSELL RAILWAY NEW BUILDING
Address: DUNKESWELL
HIGHWAY
DEVON
Postcode: EX14 4PH Date: 13/2/2020

Certificate No: 3824

Order No:

Account No:

Contact: N.F.L

Tel. No: 07818 467650

VAT Registration No. 821 9475 18

Registered in England No: 4973059

ADD/ANN/NEW

Description	CODES									
	I/S	R/C	O	N/M	U/S	ES	BS	HT	N	
Water										
Foam/Afff							5			
Dry Powder										
CO ² 2Kg							6			
CO ² 5Kg										
Labour Charge										
Fire Blanket							1			
Wet Chemical										
TOTAL							12			

Comments:

Apart from the non-conforming extinguishers as recorded, all portable fire extinguishers have been inspected and serviced in accordance with BS-5306:Part3:2009.

None Ex. Pressure
None None

Recommendation/ Quotation No.:

Appliance Removal Note No.:

CODES:

I/S - INITIAL SERVICE	N/M - NOT MAINTAINED	BS - BASIC SERVICE
R/C - RECHARGED	U/S - UNFIT FOR SERVICE	HT - HYDRAULIC TEST
O - OVERHAUL	ES - EXTENDED SERVICE	N - CONDEMNED

It is recommended that regular inspection of all extinguishers should be carried out by a responsible person at intervals, at least monthly, to make sure that appliances are in their proper position and have not been discharged or lost pressure (in cases where extinguishers are fitted with a pressure indicator), or suffered obvious damage. Any extinguishers found to be suspect should be reported and a Service Engineer called.

Code	Item	Qty	£	p
134-101	Basic Service Inspection	1		
102	Additional Extinguishers	11		
103	All Inclusive Service			
104	Trolley Unit			
105	Fire Blanket Inspection			
Code	Refills/Spare Parts Used			
134-401	Water Refill Inclusive CT/RP			
404	Foam Refill Inclusive CT/RP			
405	1 Kg ABC D/P Refill CT/RP			
406	2 Kg ABC D/P Refill CT/RP			
407	3 Kg ABC D/P Refill CT/RP			
408	4.5 Kg ABC D/P Refill CT/RP			
409	6 Kg ABC D/P Refill CT/RP			
410	9 Kg ABC D/P Refill CT/RP			
411	2 Kg ABC D/P S/Ex			
412	4.5 Kg ABC D/P S/Ex			
413	6 Kg ABC D/P S/Ex			
414	9 Kg ABC D/P S/Ex			
415	2 Kg CO ² Refill			
416	5 Kg CO ² Refill			
417	2 Kg CO ² S/Ex Inclusive H/T			
418	5 Kg CO ² S/Ex Inclusive H/T			
419	Safety Pin / Chubb			
424	Safety Pin & Clip			
425	User Guides			
427	Safety Signs			
430	Swivel Horn			
433	O-Ring			
435	Photoluminous Signs			
436	Pressure Gauge Test			
437	Wall Fixing			
438	Anti Tamper Tags			

Code	Item	Qty	£	p
439	Hose Assembly			
440	Head Assembly			
441				
Code	New			
442	2 Kg CO ² Extinguisher			
443	5 Kg CO ² Extinguisher			
444	6 Ltr AFFF Extinguisher			
445	9 Ltr AFFF Extinguisher			
446	6 Kg Dry Powder Extinguisher			
447	9 Kg Dry Powder Extinguisher			
448	9 Ltr Water Extinguisher			
449	6 Ltr Water Extinguisher			
450	6 Ltr Wet Chemical			
451	1 Kg Dry Powder			
452	2 Kg Dry Powder			
1-1	1.1 Fire Blanket			
1-2	1.2 Fire Blanket			
Service Engineer:		TOTAL		
		VAT		
Code: <u>003</u>		TOTAL DUE		
		TOTAL PAID		

Invoice Address if different than above:

Post Code:

Customer Signature: N.F.L

Print Name: N. G. WOOD

Position: MANAGER