

Cert No. 10943	Customer No. CHELBORO
<p>Tone Fire & Security Unit M, Creech Business Park Taunton Somerset TA3 5PX</p> <p>T: 01823 443832 E: admin@tonefireandsecurity.co.uk</p> <p>A BAFE Registered Company Cert No: 100583</p>	<p>Customer:</p> <p>Chelborough Ltd Clay Pigeon Raceway Wardon Hill Dorchester Dorset DT2 9PW</p>
	<p>Site: (Protected Premises)</p> <p>Chelborough Ltd Clay Pigeon Raceway Wardon Hill Dorchester Dorset DT2 9PW</p>

Portable Fire Extinguishers: Certificate of Maintenance

I/we being the technicians as indicated by my/our signatures, below, certify that, apart from non conforming extinguishers as recorded, all portable fire extinguishers, as per lists attached, have been inspected and serviced in accordance with standard BS 5306:3

Technician(s):

Signature	Name (block capitals)	BAFE ID
<i>S. Forsyth</i>	Sheldon Forsyth	

Customer:

The work as detailed has been authorised and carried out to my satisfaction. I acknowledge receipt of any recommendations and notes as attached. I acknowledge this certificate as a waste transfer note for any materials removed from site.

Signature	Name (block capitals)	Position/Rank

Date of service:

21/01/2022

No. sheets attached:

Summary of extinguishers serviced:

	Routine	Extended	Overhaul	Recharged	N/C	Commissioned
Water	1					
Foam	1					3
CO2	3		1			
Dry Powder	12				3	
Blanket						
Wet Chemical						
Totals:	17		1		3	3

